



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PROTECTION - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME MCDONALD'S				DATE 4/28/2014	SIGNATURE <i>Amanda Gaspard</i>
LOCATION 10143 SIERRA AV, FONTANA, CA 92335				REINSPECTION DATE 9/28/2014	PERMIT EXPIRATION 6/30/2014
MAILING ADDRESS 10143 SIERRA AV, FONTANA, CA 92335				REHS Amanda Gaspard	
<input checked="" type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: None	
FA # FA0009702	PR # PR0002529	SR # Not Specified	CO # Not Specified	PE 1621	SERVICE: 013 - FOOD - BILLABLE INSPECTION SERVICES
TIME IN 12:28 PM	TIME OUT 12:50 PM	CONTACT Not Captured			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RETAIL FOOD PROTECTION - PUBLIC EATING PL (25-99 SEATS)

16K993 Re-Reinspection

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments: During the routine inspection on 4-18-14, observed the following water temperature violations:

- 1) Water at 82F at the handwashing sink in the men's restroom.
- 2) Water at 74F at the handwashing sink in the women's restroom.
- 3) Water at 78F at the handwashing sink in the front service area (near the cash registers).

Facility was told to ensure that warm water (100F or above) is available at all handwashing sinks. Facility was told to correct violation within 48 hours.

During the re-inspection on 4-23-14, observed the following water temperature violations:

- 1) Water at 78F at the handwashing sink in the men's restroom. (This was the highest water temperature measured at this sink; the temperature dropped down to 76F while measuring water temperature).
- 2) Water at 80F at the handwashing sink in the women's restroom. (Temperature at this handwashing sink also began to drop while measuring water temperature.)
- 3) Water at 71F at the handwashing sink in the front service area (near the cash registers).

Facility was told to ensure that warm water (100F or above) is available at all handwashing sinks. Facility was told to correct violation within 48 hours.

During the billable re-re-inspection on 4-28-14, observed:

- 1) Water at 123F at the handwashing sink in the men's restroom.
- 2) Water at 122F at the handwashing sink in the women's restroom.
- 3) Water at 148F at the handwashing sink in the front service area (near the cash registers).

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Violation Description: Billable re-reinspection conducted at this time to determine compliance from prior reinspection.

Overall Inspection Comments

Facility is now in compliance with water temperature requirements. No further action in this area is required.

Photo Attachments:
No Photo Attachments