



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>HOTEL EXTENDED STUDIO</b>					DATE <b>4/30/2014</b>	SIGNATURE 	
LOCATION <b>14786 MONARCH BL, VICTORVILLE, CA 92395</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>PO BOX 6472, SAN DIEGO CA 92166</b>					REHS <b>Veronica Vazquez</b>		
FA # <b>FA0015403</b>	PR # <b>PR0020407</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: Spa		
TIME IN <b>2:30 PM</b>	TIME OUT <b>2:57 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

**RECREATIONAL HEALTH - PUBLIC SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**88**

SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	No Data
required flow (gpm)	24
volume (gal)	736
area (sq ft)	50
occupancy	5

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Posted closure sign for spa. Do not open spa or remove closure sign without approval from San Bernardino County Environmental Health Services.  Spa closed due to high chlorine level and low pH.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Comply by: 5/1/2014	<b>Inspector Comments:</b> Observed free chlorine residual above 25 ppm in the spa.  Immediately correct to ensure free chlorine residual does not exceed 10 ppm.  Spa is hereby closed.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Comply by: 5/1/2014	<b>Inspector Comments:</b> Observe pH below 7.0 in the spa. Immediately correct and maintain pH between 7.2 and 8.0.  Spa is hereby closed due to low/acidic pH less than 7.0.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure flow meter is repaired or replaced. Unable to read flow rate, observed flow meter stuck at zero.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>HOTEL EXTENDED STUDIO</b>	DATE <b>4/30/2014</b>	SIGNATURE 
LOCATION <b>14786 MONARCH BL, VICTORVILLE, CA 92395</b>		REHS <b>Veronica Vazquez</b>

**36K474 Lighting - Adequate Lighting and Ventilation**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Ensure the pool light is functioning. Unable to verify if working. Pool and spa are indoor with lights.
	Not In Compliance	
Violation Reference - SBCC - 3115B, 3106B, 3121B		

**Violation Description:** Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

**Overall Inspection Comments**

Spa  
Free chlorine level: 25 ppm.  
pH: below 7.0  
Cyanuric acid: 100 ppm  
Water Temperature: 102F

Posted Spa closure sign. Do not remove. Printed copy of paper report.

Call number below when spa chemicals are corrected.

Call Veronica Vazquez with questions at (800) 442-2283.

**Photo Attachments:**  
No Photo Attachments