



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>MONTIERRA APARTMENTS</b>					DATE <b>5/1/2014</b>	SIGNATURE	
LOCATION <b>1701 E D ST, ONTARIO, CA 91764</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>8/31/2014</b>	
MAILING ADDRESS <b>1701 E D ST, ONTARIO, CA 91764</b>					REHS <b>Chaz Harrison</b>		
FA # <b>FA0003650</b>	PR # <b>PR0013555</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: Office spa		
TIME IN <b>11:23 AM</b>	TIME OUT <b>11:59 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVICE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIR		
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

**RECREATIONAL HEALTH - PUBLIC SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	47
volume (gal)	1,400
area (sq ft)	56
occupancy	6

**36K995 Permit - Suspension**



POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Permit will remain suspended due to low pH levels.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K993 Re-Reinspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Re-reinspection conducted as a follow up from a re-inspection where the spa was closed due to the chlorine concentration being to low. Upon todays inspection the pH was observed below 7.0. Ensure pH is maintained between 7.2-8.0. Failure to maintain pH within these legal limits will result in closure of pool/spa.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Billable re-reinspection conducted at the time to determine compliance from prior inspection.

**Overall Inspection Comments**

pH: below 7.0

**Photo Attachments:**  
No Photo Attachments