



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>HOTEL EXTENDED STUDIO</b>				DATE <b>5/2/2014</b>	SIGNATURE	
LOCATION <b>14786 MONARCH BL, VICTORVILLE, CA 92395</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>PO BOX 6472, SAN DIEGO CA 92166</b>				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS <b>Rob Miller</b>		
FA # <b>FA0015403</b>	PR # <b>PR0020407</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: Spa	
TIME IN <b>11:34 AM</b>	TIME OUT <b>11:58 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - PUBLIC SPA**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	24
volume (gal)	736
area (sq ft)	50
occupancy	5

**36K404 Water Quality - Critical - High Disinfectant Level**



POINTS  4	Compliance Date: Not Specified	Inspector Comments:
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**Overall Inspection Comments**

Initial Chlorine level exceeded 20 ppm. Chlorine level was readjusted to 10 ppm

**Photo Attachments:**

No Photo Attachments