



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | | |
|---|----------------------------|--------------------------------|------------------------------|---|---|--|
| FACILITY NAME GOOD NITE INN | | | | DATE 5/7/2014 | SIGNATURE | |
| LOCATION 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374 | | | | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 6/30/2014 | |
| MAILING ADDRESS 1675 INDUSTRIAL PARK AV, REDLANDS, CA 92374 | | | | REHS Yong Aday | | |
| FA # FA0004817 | PR # PR0015220 | SR # Not Specified | CO # Not Specified | PE 3605 | PROGRAM IDENTIFIER: spa | |
| TIME IN 9:18 AM | TIME OUT 9:27 AM | CONTACT Not Captured | | | SERVICE: 001 - INSPECTION - ROUTINE | |
| | | | | | RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED | |
| | | | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | |

RECREATIONAL HEALTH - PUBLIC SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

100

SCORE

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | No Data |
| volume (gal) | No Data |
| area (sq ft) | No Data |
| occupancy | 6 |

36K952 Drained Pool or Spa Inspection

| | | |
|----------------------------|---------------------------------------|---|
| POINTS NA | Compliance Date: Not Specified | Inspector Comments: The spa is drained and dry at this time. The spa should be kept dry when recirculation cannot be maintained. |
| | Not In Compliance | |
| | Violation Reference - HSC | |

Violation Description: An inspection was conducted at this time on a drained pool or spa. Contact DEHS prior to filling with water and/or operating.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments