



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME EUREKA MANOR				DATE 5/13/2014	SIGNATURE	
LOCATION 1525 E EUREKA ST, SAN BERNARDINO, CA 92404				REINSPECTION DATE 11/13/2014	PERMIT EXPIRATION 3/31/2015	
MAILING ADDRESS 4900 SANTA ANITA AV UNIT 2C, EL MONTE CA 91731				REHS Cecilia Jones		
FA # FA0008381	PR # PR0015659	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: pool	
TIME IN 1:17 PM	TIME OUT 1:52 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	




RECREATIONAL HEALTH - PUBLIC POOL

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	57
volume (gal)	20,655
area (sq ft)	648
occupancy	32

36K414 Water Quality - Non-Critical - pH High/Low

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed pH testing over 8.0. Maintain between 7.2 to 8.0.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K426 Safety - Emergency Shut-Off Switch

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed emergency signs missing. Immediately provide and ensure to include facility address.
	Not In Compliance	
	Violation Reference - CCR - 3138B	

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no flotation ring or safety hook. Immediately provide.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

36K440 Enclosure - Non-Critical - Enclosure/Gates Non-Drowning Hazard

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed duct tape placed on the latch in order to keep gate unlatched and easy to enter. Cease and desist allowing this practice. Inspect latch daily in order to ensure that it is latching.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: The enclosure, doors and gates shall meet all requirements in the California Code of Regulations. Fencing/gates shall be maintained in good repair.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME EUREKA MANOR	DATE 5/13/2014	SIGNATURE
LOCATION 1525 E EUREKA ST, SAN BERNARDINO, CA 92404		REHS Cecilia Jones

36K460 Skimmers - Requirements

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed float assembly and skimmer cover missing. Immediately provide.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

Ensure that gate is latching. It has been (duct tape) with in order to ensure latch does not operate. I took off the duct tape and tested the gate. it is working however, It appears a but bent. Immediately repair.

Photo Attachments:

No Photo Attachments