



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NORTHGATE VILLAGE APTS				DATE 5/15/2014	SIGNATURE <i>James M. H. Hickey</i>
LOCATION 17251 DANTE ST, VICTORVILLE, CA 92395				REINSPECTION DATE 5/19/2014	PERMIT EXPIRATION 4/30/2014
MAILING ADDRESS 9065 HAVEN AV UNIT 100, RANCHO CUCAMONGA CA 91730-5429				REHS Veronica Vazquez	
FA # FA0003225	PR # PR0015440	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 10:20 AM	TIME OUT 11:07 AM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 14 - PERMIT SUSPD / FACILITY CLOSED FENCING

RECREATIONAL HEALTH - PUBLIC POOL



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

86

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	135
volume (gal)	48,498
area (sq ft)	1,408
occupancy	64

36K995 Permit - Suspension

CRITICAL

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool is hereby closed due to gate not self closing/latching. Posted closure sign. Do not open pool or remove closure sign without approval from San Bernardino County Environmental Health Services.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K422 Safety - Critical - Unsafe/Hazardous Conditions

CRITICAL

POINTS 4	Comply by: 5/19/2014	Inspector Comments: Immediately repair/replace pool light to be safely installed. Observed pool light unlatching from pool shell. Operator states pool will remain closed until pool light is repaired. Will reinspect.
	Not In Compliance	
	Violation Reference - CCR - 116040, 65545, 116049	

Violation Description: Every person operating or maintaining a public swimming pool must do so in a sanitary, healthful and safe manner. Unhealthful, unsafe or unsanitary conditions include, but are not limited to, the failure to meet clarity, disinfection, pH, safety or bacteriological standards, broken glass on pool deck, electrical hazard; chemical storage.

All dry-niche light fixtures, and all underwater wet-niche light fixtures operating at more than 15 volts in public swimming pools shall be protected by a ground-fault circuit interrupter in the branch circuit, and all light fixtures in public swimming pools shall have encapsulated terminals. The ground-fault circuit interrupter shall comply with Underwriter's Laboratory standards.

36K438 Enclosure - Critical - Gates Drowning Hazard

CRITICAL

POINTS 4	Comply by: 5/19/2014	Inspector Comments: Ensure pool gate is self closing and latching. Observed pool main gate not self closing/latching. Operator attempted to repair. Pool is hereby closed.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NORTHGATE VILLAGE APTS	DATE 5/15/2014	SIGNATURE <i>James M. ...</i>
LOCATION 17251 DANTE ST, VICTORVILLE, CA 92395	REHS Veronica Vazquez	

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	Inspector Comments: Provide the following signs a) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water. b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.
---------------------------	---------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3125B	Inspector Comments: Repair/replace flow meter. Observed flow meter stuck at zero.
---------------------------	------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K474 Lighting - Adequate Lighting and Ventilation

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - SBCC - 3115B, 3106B, 3121B	Inspector Comments: Verify pool light is in good repair. Unable to verify.
---------------------------	---------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------

Violation Description: Pools used at night shall be equipped with underwater lighting fixtures that will provide complete illumination to all underwater areas of the pool with no blind spots. Pool deck areas and emergency egress areas shall be provided with lighting so that persons walking on the deck can identify hazards. Lighting fixtures shall be aimed towards the deck area and away from the pool surface insofar as practical. Artificial lighting shall be provided at all spray ground pads which are used at night or which do not have adequate natural lighting so that all portions of the spray pad and deck may be seen easily.

Indoor pools, dressing rooms and toilet rooms shall be ventilated according to the requirements in Chapter 4 of the California Mechanical Code.

Overall Inspection Comments

Will reinspect gate is repaired.

Call Veronica Vazquez at (800) 442-2283 with any questions.

Photo Attachments:

No Photo Attachments