



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HILLTOP INN & SUITES					DATE 5/15/2014	SIGNATURE 	
LOCATION 16901 STODDARD WELLS RD, VICTORVILLE, CA 92394					REINSPECTION DATE 11/15/2014	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS 16901 STODDARD WELLS RD, VICTORVILLE CA 92394					REHS Veronica Vazquez		
FA # FA0004485	PR # PR0014040	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 11:12 AM	TIME OUT 11:45 AM	CONTACT Not Captured			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - PUBLIC POOL



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

92

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	42
volume (gal)	20,000
area (sq ft)	600
occupancy	30

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Provide the following pool signs. a) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures. Facility currently has artificial respiration sign only. b) The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility. c) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED." d) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
	Not In Compliance	
Violation Reference - CCR 24 - 3120B		

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Comply by: 5/16/2014	Inspector Comments: Immediately provide the following life ring and body hook. Operator states equipment will be put out by pool operator this afternoon. Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool.
	Not In Compliance	
Violation Reference - CCR - 65539		

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HILLTOP INN & SUITES	DATE 5/15/2014	SIGNATURE
LOCATION 16901 STODDARD WELLS RD, VICTORVILLE, CA 92394		REHS Veronica Vazquez

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. Observed recirculation system shut off.
	Not In Compliance Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K468 Construction - Markings

POINTS 2	Comply by: 5/19/2014	Inspector Comments: Repaint 4 1/2 mark across pool shell. Observed faded.
	Not In Compliance Violation Reference - CCR - 3110B	

Violation Description: The water depth shall be clearly marked at the following locations: maximum depth; minimum depth; each end; both sides at each end; at the break in the bottom slope between the shallow and deep portions of the pool; and along the perimeter of the pool at distances not to exceed 25 feet. Pools with a maximum water depth greater than 5 feet shall have a slip resistant tile a minimum of 4 inches and not greater than 6 inches wide of a color contrasting with the background of the pool shell across the bottom of the pool where the water depth is 4 1/2 feet. For pool water depths 6 feet and shallower no diving markers with the universal symbol of no diving shall be installed on the deck directly adjacent to the depth markers.

No markings, designs or lettering shall be permitted on the pool shell except for slip resistant lane markings, depth marking lines and safety markings.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with any questions.

Photo Attachments:

No Photo Attachments