



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME ASPEN CLUBHOUSE					DATE 5/19/2014	SIGNATURE	
LOCATION 10741 LAKESHORE DR, APPLE VALLEY, CA 92308					REINSPECTION DATE 11/19/2014	PERMIT EXPIRATION 10/31/2014	
MAILING ADDRESS 19311 JESS RANCH PKWY, APPLE VALLEY CA 92308					REHS Melissa Nano		
FA # FA0014985	PR # PR0019814	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: outdoor small pool		
TIME IN 1:41 PM	TIME OUT 2:10 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - PUBLIC POOL




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	62
volume (gal)	22,530
area (sq ft)	707
occupancy	35

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed gate east of lower pool unable to completely self-latch. Pool maintenance was able to correct on site so that gate is able to securely close. Maintain gates so that they are able to self-close and self-latch.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

Overall Inspection Comments

Refer to large pool inspection report for common area violations.

Photo Attachments:

No Photo Attachments