



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CREEKSIDE WEST VILLAGE				DATE 5/19/2014	SIGNATURE	
LOCATION 2802 DEER CREEK LOOP, ONTARIO, CA 91761				REINSPECTION DATE 6/02/2014	PERMIT EXPIRATION 2/28/2015	
MAILING ADDRESS 9267 HAVEN AV STE 235, RANCHO CUCAMONGA CA 91730				REHS Veronica Martinez		
FA # FA0005777	PR # PR0014952	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Wading Pool	
TIME IN 3:18 PM	TIME OUT 3:48 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED	
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	

RECREATIONAL HEALTH - PUBLIC POOL



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

86

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: **Not Specified**
Not In Compliance
Violation Reference - **HSC**

Inspector Comments: Wading Pool permit has been suspended due to low chlorine level below 0.5 ppm. Ensure chlorine level is achieved at a minimum of 1.0 (1.5 ppm if cyanuric acid present).

Contact Division of Environmental Health Services (DEHS) at 1800-442-2283 when ready to re-open.

Do not open wading pool unless authorized by DEHS. Non-compliance will result in charged re-inspection at \$245 per hour.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: **Not Specified**
Not In Compliance
Violation Reference - **CCR - 65529**

Inspector Comments: Observed Chlorine level <.5 ppm. Ensure that free Chlorine residual is maintained at a minimum of 1.0 ppm. Facility closed, call for re-inspection.

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K416 Water Quality - Non-Critical - Clarity

POINTS
2

Compliance Date: **Not Specified**
Not In Compliance
Violation Reference - **CCR - 65527, 65543**

Inspector Comments: Observed a yellow-green appearance to water inside wading pool. Maintain proper chlorine levels and run recirculation system to ensure cleanliness of water.

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CREEKSIDE WEST VILLAGE	DATE 5/19/2014	SIGNATURE
LOCATION 2802 DEER CREEK LOOP , ONTARIO, CA 91761	REHS Veronica Martinez	

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR 24 - 3120B	Inspector Comments: Active diarrhea sign not posted at entrance to pool (sign in pump room). Post sign at entrance to pool. Observed existing sign stating "children under the age of 14 should not use pool without a parent or adult guardian in attendance" with incorrect verbage. Replace sign with correct verbage "shall" instead of "should". Observed sign missing for nearest emergency facility telephone number. Post sign indicating emergency facility telephone number.
---------------------------	---	---

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3125B	Inspector Comments: Observed stuck flow meter. Clean, repair or replace, as needed to ensure detectable flow rate.
---------------------------	--	---

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K462 Plumbing - Backflow Protection

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 3141B, 3118B	Inspector Comments: Observed direct connection between backwash line and recirculation return line. Ensure there is no direct connection from backwash line to wading pool return line and ensure corrected backwash line has a 1" minimum air gap to sewer.
---------------------------	---	---

Violation Description: There shall be no direct connection between any potable water supply system and the pool or its piping system unless protected by a backflow prevention device in accordance with Chapter 6 of the California Plumbing Code. There shall be no direct connection between the pool, its recirculation system or overflow drain to any sanitary sewer, storm drain or drainage system. Potable water outlets with hose attachments shall be protected by a nonremovable hose bibb backflow preventer, a nonremovable hose bibb vacuum breaker, or by an atmospheric vacuum breaker.

36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain

POINTS 2	Compliance Date: Not Specified Not In Compliance Violation Reference - CCR - 65535, 65551, 3117B	Inspector Comments: Observed lack of hot water in restrooms and shower. Ensure hot water is available to provide temperate (lukewarm) water at faucets and showers.
---------------------------	--	--

Violation Description: Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

Overall Inspection Comments



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CREEKSIDE WEST VILLAGE	DATE 5/19/2014	SIGNATURE
LOCATION 2802 DEER CREEK LOOP , ONTARIO, CA 91761		REHS Veronica Martinez

Chlorine: <0.5 ppm

pH: 7.6

Cyanuric acid: 60 ppm

Flow: n/a

Photo Attachments:

No Photo Attachments