



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>VILLAGE AT SIERRA</b>				DATE <b>5/21/2014</b>	SIGNATURE 
LOCATION <b>8684 SIERRA AV, FONTANA, CA 92335</b>				REINSPECTION DATE <b>11/21/2014</b>	PERMIT EXPIRATION <b>12/31/2014</b>
MAILING ADDRESS <b>8684 SIERRA AV, FONTANA, CA 92335</b>				REHS <b>Chris Nwadike</b>	
FA # <b>FA0010977</b>	PR # <b>PR0013897</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool
TIME IN <b>5:08 PM</b>	TIME OUT <b>5:33 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - PUBLIC POOL**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**98**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	78.0
observed flow (gpm)	0
required flow (gpm)	73
volume (gal)	26,265
area (sq ft)	824
occupancy	41

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed cyanuric acid level at more than 100.0ppm. Maintain below 100.0ppm. Drain, wash and refill the pool.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments