



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>RAINTREE GARDENS</b>				DATE <b>5/23/2014</b>	SIGNATURE	
LOCATION <b>18125 BELLFLOWER, ADELANTO, CA 92301</b>				REINSPECTION DATE <b>11/23/2014</b>	PERMIT EXPIRATION <b>5/31/2014</b>	
MAILING ADDRESS <b>2060 E AVENIDA DE LOS ARBOLES STE D, THOUSAND OAKS CA 91362-1376</b>				REHS <b>Dawn LaFlower</b>		
FA # <b>FA0008631</b>	PR # <b>PR0013611</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool	
TIME IN <b>12:02 PM</b>	TIME OUT <b>12:28 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - PUBLIC POOL**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**92**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	78
volume (gal)	28,000
area (sq ft)	936
occupancy	46

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Maintain free chlorine between 1.5 and 10.0 ppm.
	Not In Compliance	Observed measuring 0.5 ppm. Manager immediately added chlorine.
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**36K414 Water Quality - Non-Critical - pH High/Low**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Maintain pH between 7.2 and 8.0.
	Not In Compliance	Observed measuring 8.2. Manager immediately added muriatic acid.
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>RAINTREE GARDENS</b>	DATE <b>5/23/2014</b>	SIGNATURE
LOCATION <b>18125 BELLFLOWER, ADELANTO, CA 92301</b>	REHS <b>Dawn LaFlower</b>	

**36K427 Safety - Safety Signs**

<b>POINTS</b>  <div style="border: 1px solid black; padding: 5px; text-align: center; font-size: 24px;"><b>2</b></div>	<b>Compliance Date: Not Specified</b> <b>Not In Compliance</b> <b>Violation Reference - CCR 24 - 3120B</b>	<b>Inspector Comments:</b> Provide the following information and signs:  An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.  The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.  Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."  A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".  A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
--	--	--

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K448 Equipment - Flow Meter**

<b>POINTS</b>  <div style="border: 1px solid black; padding: 5px; text-align: center; font-size: 24px;"><b>2</b></div>	<b>Compliance Date: Not Specified</b> <b>Not In Compliance</b> <b>Violation Reference - CCR - 3125B</b>	<b>Inspector Comments:</b> Repair/replace flow meter and maintain a minimum flow rate of 78 gpm.  Observed flow meter not functioning and leaking.
--	---	--

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments