



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN EXPRESS HOTEL & SUITES BARSTOW				DATE 5/27/2014	SIGNATURE
LOCATION 2700 LENWOOD RD, BARSTOW, CA 92311				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014
MAILING ADDRESS 40820 SIERRA DR, THREE RIVERS CA 93271				REHS Dawn LaFlower	
FA # FA0010986	PR # PR0013896	SR # Not Specified	CO # Not Specified	PE 3605	PROGRAM IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE
TIME IN 11:26 AM	TIME OUT 11:52 AM	CONTACT Not Captured			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - PUBLIC SPA



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

86

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	107.0
observed flow (gpm)	0
required flow (gpm)	53
volume (gal)	1,307
area (sq ft)	64
occupancy	6

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Maintain pH measuring between 7.2 and 8.0.
	Not In Compliance	Observed measuring significantly below 7.0. Corrected to 7.6
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

36K420 Temperature - Critical - Spa Water Requirement

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Ensure temperature of spa water does not exceed 104 degrees.
	Not In Compliance	Observed measuring 107 degrees.
	Violation Reference - CCR 24 - 3138B	

Violation Description: The allowable water temperature of a spa pool shall not exceed 104°F.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Ensure cyanuric acid concentration does not exceed 100 ppm.
	Not In Compliance	Observed exceeding way over 100 ppm. Recommend maintaining between 10 and 50 ppm.
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Provide labeling on recirculation pipes that shows the direction of flow.
	Not In Compliance	Observed none.
	Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN EXPRESS HOTEL & SUITES BARSTOW		DATE 5/27/2014	SIGNATURE 
LOCATION 2700 LENWOOD RD, BARSTOW, CA 92311		REHS Dawn LaFlower	

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Repair/replace flow meter and maintain a minimum flow rate of 53 gpm.
	Not In Compliance	Observed flow meter not functioning.
Violation Reference - CCR - 3125B		

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments