



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>MOUNTAIN VIEW VILLAS</b>				DATE <b>5/27/2014</b>	SIGNATURE <i>[Signature]</i>
LOCATION <b>21621 SANDIA RD, APPLE VALLEY, CA 92307</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2015</b>
MAILING ADDRESS <b>21621 SANDIA RD, APPLE VALLEY, CA 92307</b>				REHS <b>Melissa Nano</b>	
FA # <b>FA0004732</b>	PR # <b>PR0016259</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: spa
TIME IN <b>11:51 AM</b>	TIME OUT <b>12:25 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
				RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
				ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - PUBLIC SPA**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	99.0
observed flow (gpm)	No Data
required flow (gpm)	65
volume (gal)	23,600
area (sq ft)	1,000
occupancy	50

**36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed chlorine level at 1.0 ppm. When using cyanuric acid, maintain chlorine levels between 1.5- 10 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Install missing sight glass on back wash piping between filter and separation tank.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Obtain missing float assembly for skimmer system.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**

Please refer to pool inspection report for common area violations.

Please contact DEHS Plan Check prior to any construction or alteration of pool and/ or spa.

**Photo Attachments:**

No Photo Attachments