



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | | | |
|---|----------------------------|--------------------------------|------------------------------|-------------------|--|---------------------------------------|--|
| FACILITY NAME AMARPAN LLC | | | | | DATE 5/27/2014 | SIGNATURE | |
| LOCATION 22526 SIOUX RD, APPLE VALLEY, CA 92308 | | | | | REINSPECTION DATE 11/27/2014 | PERMIT EXPIRATION 5/31/2014 | |
| MAILING ADDRESS 2359 SKYLINE DR, FULLERTON CA 92831 | | | | | REHS Melissa Nano | | |
| FA # FA0005825 | PR # PR0014084 | SR # Not Specified | CO # Not Specified | PE 3601 | PROGRAM IDENTIFIER: pool SERVICE: 001 - INSPECTION - ROUTINE | | |
| TIME IN 2:30 PM | TIME OUT 3:25 PM | CONTACT Not Captured | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ ACTION: 01 - NO FURTHER ACTION REQUIRED | | |

RECREATIONAL HEALTH - PUBLIC POOL




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | No Data |
| required flow (gpm) | 50 |
| volume (gal) | 17,000 |
| area (sq ft) | 570 |
| occupancy | 28 |

36K442 Equipment - Critical - Non-Functioning Recirculation System

⚠ CRITICAL ⚠

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 4 | Compliance Date: Not Specified | Inspector Comments: Observed pump/recirculation system off during operating hours. Facility was already closed for maintenance. Ensure recirculation system is on during pool operating hours. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65525 | |

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use.

36K427 Safety - Safety Signs

| | | |
|---------------------------|--------------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Obtain and post the following missing signs: "Keep Gate Closed" (Post on exterior of gate entrance) "Active Diarrhea" (Post where it is visible upon entry) "Local Emergency" "Facility name and address" |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | |
|---|--------------------------|-----------------------------|
| FACILITY NAME AMARPAN LLC | DATE 5/27/2014 | SIGNATURE |
| LOCATION 22526 SIOUX RD, APPLE VALLEY, CA 92308 | | REHS Melissa Nano |

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

| | | |
|---------------------------|--|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Indicate and label, using arrows, the direction of flow of water on piping of recirculation system. Maintain a one inch air gap between backwash pipe and sewer system. |
| | Not In Compliance Violation Reference - HSC - 3120B, 3132B, 3141B | |

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K460 Skimmers - Requirements

| | | |
|---------------------------|---|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Obtain missing float assembly for both skimmer systems. |
| | Not In Compliance Violation Reference - CCR - 65533, 3136B | |

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

Overall Inspection Comments

Recirculation system was observed off upon inspection. Facility was already closed and locked from public use due to pool maintenance. Ensure the recirculation system is on during pool operation hours.

Photo Attachments:

No Photo Attachments