



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VISTA DEL ROSA				DATE 5/28/2014	SIGNATURE <i>[Signature]</i>
LOCATION 22241 NISQUALLY RD, APPLE VALLEY, CA 92308				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 9/30/2014
MAILING ADDRESS 22241 NISQUALLY RD, APPLE VALLEY, CA 92308				REHS Melissa Nano	
FA # FA0004613	PR # PR0013567	SR # Not Specified	CO # Not Specified	PE 3605	PROGRAM IDENTIFIER: spa
TIME IN 10:55 AM	TIME OUT 11:30 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - PUBLIC SPA




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	101.0
observed flow (gpm)	No Data
required flow (gpm)	38
volume (gal)	1,128
area (sq ft)	50
occupancy	5

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed chlorine level over 10 ppm. Pool maintenance corrected on site to 10 ppm. Maintain chlorine levels between 1.5 - 10 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid levels at 110 ppm. Maintain levels so that it does not exceed 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

Please refer to pool inspection report for common area violations.

Photo Attachments:

No Photo Attachments