



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>MOUNTAIN VIEW SPRING ESTATES HOA</b>					DATE <b>5/28/2014</b>	SIGNATURE	
LOCATION <b>1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410</b>					REINSPECTION DATE <b>11/28/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410</b>					REHS <b>John Babalola</b>		
FA # <b>FA0008858</b>	PR # <b>PR0014215</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN <b>2:10 PM</b>	TIME OUT <b>3:14 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ ACTION: 01 - NO FURTHER ACTION REQUIRED		

**RECREATIONAL HEALTH - PUBLIC POOL**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**80**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	0
required flow (gpm)	57
volume (gal)	20,655
area (sq ft)	648
occupancy	32

**36K402 Water Quality - Critical - Lack of Disinfectant**



<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	Inspector Comments: The free chlorine level is observed at 0.5 ppm. Provide at least 1.5 ppm at all times.
	Not In Compliance	Note: Correction is being made.
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: The cyanuric acid level is observed above 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Provide the phone number for the nearest emergency services and the name and address of the facility at the pool side. None observed.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>MOUNTAIN VIEW SPRING ESTATES HOA</b>	DATE <b>5/28/2014</b>	SIGNATURE
LOCATION <b>1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410</b>	REHS <b>John Babalola</b>	

**36K430 Safety - Equipment/First Aid Kit**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Immediately, replace the missing rescue pole.
	Not In Compliance	
	Violation Reference - CCR - 65539	

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> No flow direction labels observed in the equipment room.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**36K446 Equipment - Chlorinator/Heater/Jets**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> The automatic chlorinator is empty at the time of inspection. Refill with chlorine tablets .
	Not In Compliance	Immediately, discontinue the practice of putting chlorine tablets inside the skimmer.
	Violation Reference - CCR - 65529, 65535, 3134B...	

**Violation Description:** Pools, when open or in use, shall be disinfected continuously by a chemical which imparts a residual effect. Disinfectant feeders shall comply with applicable requirements established by the NSF/ANSI 50-2010 performance standard effective August 2010 for disinfectant feeders. All feeders shall be capable of supplying not less than the equivalent of 3 pounds of 100 percent available chlorine per day per 10,000 gallons of pool water capacity. All parts of the pool and related pool facilities and equipment shall be maintained in good repair. A spa pool aeration and/or jet system shall be completely separate from the recirculation system and shall not be interconnected with any other pool.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Repair/replace the non-functional flow meter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K450 Equipment - Gauges**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Replace the damaged influent pressure gauge.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A pressure and vacuum gauge shall be provided for each pump system and shall be accurate within 2 percent of scale.

**36K460 Skimmers - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Replace the missing skimmer weir gates.
	Not In Compliance	
	Violation Reference - CCR - 65533, 3136B	

**Violation Description:** The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.

**Overall Inspection Comments**



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME MOUNTAIN VIEW SPRING ESTATES HOA	DATE 5/28/2014	SIGNATURE
LOCATION 1979 SPRING MOUNTAIN TR, SAN BERNARDINO, CA 92410	REHS John Babalola	

Provide the keys to the pool gates and the equipment room to our office.

Attention of John Babalola  
Environmental Health Services  
385 N. Arrowhead Ave, 2nd Floor  
San Bernardino, CA 92415-0160.

(800)442-2283.

**Photo Attachments:**  
No Photo Attachments