



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>BROOKSIDE PARK APTS</b>					DATE <b>5/29/2014</b>	SIGNATURE <b>FIOLEN</b>	
LOCATION <b>1264 BROOKSIDE AV, REDLANDS, CA 92373</b>					REINSPECTION DATE <b>6/12/2014</b>	PERMIT EXPIRATION <b>6/30/2014</b>	
MAILING ADDRESS <b>1350 MILBURN AV, REDLANDS CA 92373</b>					REHS <b>Robert Adams</b>		
FA # <b>FA0008759</b>	PR # <b>PR0014279</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: Pool F - east of office pool/spa (D)		
TIME IN <b>11:27 AM</b>	TIME OUT <b>12:13 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 03 - REINSPECTION REQUIRED		

**RECREATIONAL HEALTH - Public Pool**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**82**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K422 Safety - Critical - Unsafe/Hazardous Conditions**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed nonfunctional GFCI in the pool. Repair or replace GFCI.
	Not In Compliance	
Violation Reference - CCR - 116040, 65545, 116049		

**Violation Description:** Every person operating or maintaining a public swimming pool must do so in a sanitary, healthful and safe manner. Unhealthful, unsafe or unsanitary conditions include, but are not limited to, the failure to meet clarity, disinfection, pH, safety or bacteriological standards, broken glass on pool deck, electrical hazard; chemical storage.

All dry-niche light fixtures, and all underwater wet-niche light fixtures operating at more than 15 volts in public swimming pools shall be protected by a ground-fault circuit interrupter in the branch circuit, and all light fixtures in public swimming pools shall have encapsulated terminals. The ground-fault circuit interrupter shall comply with Underwriter's Laboratory standards.

**36K430 Safety - Equipment/First Aid Kit**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pool with missing life hook. Provide life hook within 72 hours. Ensure all critical violations are corrected prior to calling for reinspection. If violations are still observed additional charged reinspection may be needed to reopen your spa. Charged reinspection will be charged at the rate of 245.00 per hour with a minimum charge of one half hour.
	Not In Compliance	
Violation Reference - CCR - 65539		

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>BROOKSIDE PARK APTS</b>	DATE <b>5/29/2014</b>	SIGNATURE <b>[Signature]</b>
LOCATION <b>1264 BROOKSIDE AV, REDLANDS, CA 92373</b>	REHS <b>Robert Adams</b>	

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed safety signs missing CPR, local ems, and address of the pool information. Provide CPR and artificial respiration information. Provide local EMS phone # and address of the pool.
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed missing directional arrows to indicate the flow of pool equipment. Provide directional arrows.
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**36K446 Equipment - Chlorinator/Heater/Jets**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed 3lb chlorinator used at a 14000 gallon pool. Ensure chlorinator is properly sized to provide at least 3lbs per 10000 gallons pool capacity.
	Violation Reference - CCR - 65529, 65535, 3134B...	

**Violation Description:** Pools, when open or in use, shall be disinfected continuously by a chemical which imparts a residual effect. Disinfectant feeders shall comply with applicable requirements established by the NSF/ANSI 50-2010 performance standard effective August 2010 for disinfectant feeders. All feeders shall be capable of supplying not less than the equivalent of 3 pounds of 100 percent available chlorine per day per 10,000 gallons of pool water capacity. All parts of the pool and related pool facilities and equipment shall be maintained in good repair. A spa pool aeration and/or jet system shall be completely separate from the recirculation system and shall not be interconnected with any other pool.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified Not In Compliance	<b>Inspector Comments:</b> Observed nonfunctional flow meter. Provide a functioning flow meter.
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>BROOKSIDE PARK APTS</b>	DATE <b>5/29/2014</b>	SIGNATURE <b>[Signature]</b>
LOCATION <b>1264 BROOKSIDE AV, REDLANDS, CA 92373</b>		REHS <b>Robert Adams</b>

**36K468 Construction - Markings**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed missing depth marker at the deep end of the pool. Replace depth marker on the deck.
	<b>Not In Compliance</b>	
Violation Reference - <b>CCR - 3110B</b>		

**Violation Description:** The water depth shall be clearly marked at the following locations: maximum depth; minimum depth; each end; both sides at each end; at the break in the bottom slope between the shallow and deep portions of the pool; and along the perimeter of the pool at distances not to exceed 25 feet. Pools with a maximum water depth greater than 5 feet shall have a slip resistant tile a minimum of 4 inches and not greater than 6 inches wide of a color contrasting with the background of the pool shell across the bottom of the pool where the water depth is 4 1/2 feet. For pool water depths 6 feet and shallower no diving markers with the universal symbol of no diving shall be installed on the deck directly adjacent to the depth markers.

No markings, designs or lettering shall be permitted on the pool shell except for slip resistant lane markings, depth marking lines and safety markings.

**36K476 Decking - Requirements**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed expansion joints in disrepair. Repair or replace expansion joints.
	<b>Not In Compliance</b>	
Violation Reference - <b>CCR - 3114B</b>		

**Violation Description:** A minimum continuous and unobstructed 4-foot wide slip resistant, cleanable, nonabrasive deck area of concrete or like material shall be provided flush with the top of the pool coping extending completely around the pool, and the deck area shall further extend 4 feet both sides and rear of any diving board, fixed disabled access assistance device or slide and their appurtenances. Deck shall be maintained in good repair.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments