



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME FAIRWAY COURT HOA				DATE 5/30/2014	SIGNATURE	
LOCATION 27535 LAKEVIEW DR, HELENDALE, CA 92342				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 7/31/2014	
MAILING ADDRESS 12176 INDUSTRIAL BL UNIT 1, VICTORVILLE CA 92393				REHS Veronica Vazquez		
FA # FA0008109	PR # PR0014634	SR # Not Specified	CO # Not Specified	PE 3605	PROGRAM IDENTIFIER: Spa	
TIME IN 11:15 AM	TIME OUT 11:35 AM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
				RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
				ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - Public Spa




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	104.0
observed flow (gpm)	40
required flow (gpm)	117
volume (gal)	3,500
area (sq ft)	144
occupancy	14

36K418 Water Quality - Cyanurates

POINTS
2

Compliance Date: Not Specified
 Not In Compliance
 Violation Reference - CCR - 65529

Inspector Comments: Observed cyanuric acid acid above 100 ppm in the spa water.

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

Overall Inspection Comments

Verify spa light is in good repair.

Call Veronica Vazquez at (800) 442-2283 with any questions.

Photo Attachments:

No Photo Attachments