





County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME SPRING VALLEY LAKE COUNTRY CLUB				DATE 6/4/2014	SIGNATURE <i>Debra Smith</i>
LOCATION 13229 SPRING VALLEY LAKE PKWY, VICTORVILLE, CA 92392				REINSPECTION DATE 11/04/2014	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 7070 SVL BOX, VICTORVILLE CA 92392				REHS Veronica Vazquez	
FA # FA0006828	PR # PR0014766	SR # Not Specified	CO # Not Specified	PE 3601	PROGRAM IDENTIFIER: Pool
TIME IN 2:13 PM	TIME OUT 2:47 PM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	338
volume (gal)	160,000
area (sq ft)	1,800
occupancy	150

36K994 Reinspection

POINTS	Comply by: 6/6/2014
NA	Not In Compliance
	Violation Reference - HSC

Inspector Comments: Observed pool gate on south of pool deep end repaired to self close and latch.

Ensure all doors leading to pool area are self closing and latching. Observed two door entrance to pool by snack bar left open with a rock.

Operator states door is left open to avoid inactivating the card swipe machine. Ensure to keep closed unless supervision is provided by the entrance e.g. lifeguard.

Operator closed two door entrance to pool by snack bar. Observed air slowing down the closure of door. Repair.

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with any questions.

Photo Attachments:

No Photo Attachments