



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>FOREST HOME CHRISTIAN CC</b>				DATE <b>6/5/2014</b>	SIGNATURE	
LOCATION <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS, CA 92339</b>				REINSPECTION DATE <b>6/19/2014</b>	PERMIT EXPIRATION <b>12/31/2014</b>	
MAILING ADDRESS <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS CA 92339</b>				REHS <b>Antonio Fields</b>		
FA # <b>FA0008307</b>	PR # <b>PR0035977</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3632</b>	PROGRAM IDENTIFIER: <b>SPLASH PAD</b>	
TIME IN <b>12:17 PM</b>	TIME OUT <b>12:56 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - INSPECTION - ROUTINE</b>	
					RESULT: <b>05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED</b>	
					ACTION: <b>13 - PERMIT SUSPENDED / FACILITY CLOSED</b>	

**RECREATIONAL HEALTH - Organized Camp Pool**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**90**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

POINTS <b>NA</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Permit suspended and splash pad closed due to unsafe chlorine and pH levels.
	Not In Compliance	
	Violation Reference - <b>HSC</b>	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**

**⚠ CRITICAL ⚠**

POINTS <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed the free chlorine concentration above 20 ppm. Maintain the free chlorine concentration between 1.5 - 10ppm (minimum 1.0 when cyanuric acid is not present).
	Not In Compliance	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

POINTS <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed the pH less than 7.0 in the splash pad area. Maintain the pH between 7.2-8.0.
	Not In Compliance	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>FOREST HOME CHRISTIAN CC</b>	DATE <b>6/5/2014</b>	SIGNATURE
LOCATION <b>40000 VALLEY OF THE FALLS DR, FOREST FALLS, CA 92339</b>		REHS <b>Antonio Fields</b>

**36K427 Safety - Safety Signs**

<b>POINTS</b>  <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Ensure a sign is visible at the spray ground stating "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK." Sign observed missing.
	Not In Compliance	
	Violation Reference - <b>CCR 24 - 3120B</b>	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments