



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>MOTEL 6 4731</b>				DATE <b>6/5/2014</b>	SIGNATURE	
LOCATION <b>1560 E 4TH ST, ONTARIO, CA 91764</b>				REINSPECTION DATE <b>11/05/2014</b>	PERMIT EXPIRATION <b>4/30/2014</b>	
MAILING ADDRESS <b>1260 UNIVERSITY AV, RIVERSIDE CA 92507</b>				REHS <b>Anies Kondoker</b>		
FA # <b>FA0008580</b>	PR # <b>PR0015174</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: pool	
TIME IN <b>9:28 AM</b>	TIME OUT <b>9:51 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED	

**RECREATIONAL HEALTH - Public Pool**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	40
volume (gal)	16,500
area (sq ft)	545
occupancy	27

**36K992 Permit Reinstatement**

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: _____
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: The health permit to operate is hereby reinstated and facility may open.

**36K994 Reinspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: _____
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

- Increase pH to t.2 - 8.0.
  - Observed debris on pool bottom. Maintain clean.
- Operator stated that a pool technician will come today or tomorrow to take care of the pool.
- Repair/replace non-functional flow meter.
  - Correct the remaining violations listed on a routine inspection report last week.

Photo Attachments:  
No Photo Attachments