



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>LA FITNESS</b>				DATE <b>6/5/2014</b>	SIGNATURE 
LOCATION <b>16289 SIERRA LAKES PKWY, FONTANA, CA 92335</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>2/28/2015</b>
MAILING ADDRESS <b>PO BOX 52110, IRVINE CA 92619-2110</b>				REHS <b>Chris Nwadike</b>	
FA # <b>FA0016070</b>	PR # <b>PR0021374</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3605</b>	PROGRAM IDENTIFIER: spa
TIME IN <b>4:21 PM</b>	TIME OUT <b>5:19 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

**RECREATIONAL HEALTH - Public Spa**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	104.9
observed flow (gpm)	75
required flow (gpm)	74
volume (gal)	2,223
area (sq ft)	114
occupancy	11

**36K420 Temperature - Critical - Spa Water Requirement**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed the water temperature at 104.9°F. Maintain at, or below 104°F.
	Not In Compliance	
	Violation Reference - CCR 24 - 3138B	

**Violation Description:** The allowable water temperature of a spa pool shall not exceed 104°F.

**36K444 Equipment - Recirculation Pump/Filter/Separation Tank**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no labels/markings showing the direction of water recirculation on all piping in the pump room. Label/mark the direction of water recirculation on all piping in the pump room.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments