



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>DEER PARK RESORT</b>				DATE <b>6/5/2014</b>	SIGNATURE 
LOCATION <b>1924 GLEN HELEN RD, DEVORE, CA 92407</b>				REINSPECTION DATE <b>12/05/2014</b>	PERMIT EXPIRATION <b>12/31/2014</b>
MAILING ADDRESS <b>1770 N ARROWHEAD AV, SAN BERNARDINO CA 92405</b>				REHS <b>Marilyn Krichbaum</b>	
FA # <b>FA0006742</b>	PR # <b>PR0015776</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3601</b>	PROGRAM IDENTIFIER: <b>Upper Pool</b>
TIME IN <b>10:10 AM</b>	TIME OUT <b>10:50 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - INSPECTION - ROUTINE</b>
					RESULT: <b>03 - CORRECTIVE ACTION / NO FOLLOW UP REQ</b>
					ACTION: <b>01 - NO FURTHER ACTION REQUIRED</b>

**RECREATIONAL HEALTH - Public Pool**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**82**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	100
required flow (gpm)	109
volume (gal)	52,500
area (sq ft)	1,056
occupancy	78

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed a low ph level of 7.0. Immediately raise the ph level so that it is 7.2-8.0. Employee made the chemical adjustment.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K436 Enclosure - Critical - Enclosure Drowning Hazard**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed that the public has access to the pool from the upper patio deck area. Observed that a smart part of the fence is made of rocks and is 35-37 inches high on the inside and is readily accessed from the outside perimeter. This does not meet the new fencing requirements which are 5 feet high as measured from the outside perimeter. Install new fencing in this area, 5 feet high, with gaps no more than 4 inches in any dimension, 2 inches above grade. The fencing materials must be of material that is not climbable. See the attached code section.
	Not In Compliance	
	Violation Reference - CCR 24 - 3119B	

**Violation Description:** The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows gates of living units or associated private premises shall not be permitted as part of the pool enclosure. The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children.

**36K438 Enclosure - Critical - Gates Drowning Hazard**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed that one gate, service entrance for employees, had no self latching device. Immediately install a self latching device on gate.  Observed several open gates. Make sure gates are kept closed and are self closing and self latching.  At the end of the inspection employee installed a chain and locked the gate up.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed a cyanuric acid level greater than 100ppm. Lower the cyanuric acid level so that it is below 100ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>DEER PARK RESORT</b>	DATE <b>6/5/2014</b>	SIGNATURE 
LOCATION 1924 GLEN HELEN RD, DEVORE, CA 92407		REHS <b>Marilyn Krichbaum</b>

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Replace the following missing signs: Provide the keep closed sign on the exterior side of all gates. Provide the name and address of facility on the sign. Provide the emergency services telephone number on the sign, other than 911. Provide the number on the pool capacity sign.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

**36K482 Restrooms - Toilet Facilities - Showers - Drinking Fountain**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed no hot water in the handicapped restroom. Provide hot water to this sink.  Replace the damaged sink in the womens restroom. Replace the missing lid over toilet.
	Not In Compliance	
	Violation Reference - CCR - 65535, 65551, 3117B	

**Violation Description:** Toilets, urinals, showers, wash basins and other plumbing fixtures shall be maintained in a clean condition, and in good repair. For shower, toilet and dressing facilities, the walls, partitions, doors, lockers and similar surfaces which require periodic cleaning shall be maintained smooth and finished so as to facilitate cleaning. Showers shall be provided with soap in soap dispensers or containers. For toilet facilities, handwashing detergent or soap, sanitary towels or hot air blowers, and toilet tissues shall be provided in permanently installed dispensing devices. Showers and lavatories shall be provided with hot and cold water faucets.

One guarded jet drinking fountain shall be provided for the first 250 bathers and an additional fountain shall be provided for each additional 200 bathers or fraction thereof.

**Overall Inspection Comments**

Label the flow of the water thru the recirculation system on the pool piping by using arrows.

**Photo Attachments:**

No Photo Attachments