



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VILLA BONITA					DATE 6/6/2014	SIGNATURE	
LOCATION 1910 ORANGE AV, REDLANDS, CA 92373					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2013	
MAILING ADDRESS 2400 MAIN ST, IRVINE CA 92614					REHS Robert Adams		
FA # FA0027005	PR # PR0035335	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa		
TIME IN 12:10 PM	TIME OUT 1:18 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	102.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K404 Water Quality - Critical - High Disinfectant Level

⚠ **CRITICAL** ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed chlorine greater than 10ppm. Ensure chlorine is maintained between 1.5 and 10ppm. This is a closure item. A reinspection will be required to reopen the spa for this violation. Correct violation and call 800-442-2283 for reinspection.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K426 Safety - Emergency Shut-Off Switch

⚠ **CRITICAL** ⚠

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed emergency shut off switch only shutting off booster pump for jets. Recirculation pump is not shutting off when the switch is activated. Repair shut off switch. This is a closure item. A reinspection will be required to reopen the spa for this violation. Correct violation and call 800-442-2283 for reinspection.
	Not In Compliance	
	Violation Reference - CCR - 3138B	

Violation Description: A clearly labeled emergency shut off switch for the control of both the recirculation system and the aeration and/or jet system shall be installed adjacent to the spa pool.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid at greater than 100ppm. Ensure cyanuric acid is maintained at less than 100ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME VILLA BONITA	DATE 6/6/2014	SIGNATURE
LOCATION 1910 ORANGE AV, REDLANDS, CA 92373	REHS Robert Adams	

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed diarrhea sign not visible from the entrance to the pool. Observed missing CPR information and pool / spa capacity. Provide a diarrhea sign visible from the entrance of the pool enclosure. Provide CPR information in addition to artificial respiration info. Provide pool and spa capacity.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

Ensure all critical violations are corrected prior to calling for reinspection. If violations are still observed additional charged reinspection may be needed to reopen. Charged reinspection will be charged at the rate of 245.00 per hour with a minimum charge of one half hour.

Photo Attachments:

No Photo Attachments