



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>VALENCIA LEA MHP</b>				DATE <b>6/9/2014</b>	SIGNATURE 
LOCATION <b>3850 E ATLANTIC AV, HIGHLAND, CA 92346</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>
MAILING ADDRESS <b>3850 E ATLANTIC AV 39, HIGHLAND CA 92346</b>				REHS <b>Marilyn Krichbaum</b>	
FA # <b>FA0008812</b>	PR # <b>PR0014233</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa
TIME IN <b>12:00 PM</b>	TIME OUT <b>12:30 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**88**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	98.0
observed flow (gpm)	No Data
required flow (gpm)	44
volume (gal)	1,320
area (sq ft)	80
occupancy	8

**36K404 Water Quality - Critical - High Disinfectant Level**



<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed a very high chlorine level greater than 10ppm. Immediately lower the chlorine level so that it is 1.5ppm not to exceed 10ppm. Posted closed sign. Call me for reinspection at 1-800-442-2283.
	Not In Compliance Violation Reference - CCR - 65529	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K414 Water Quality - Non-Critical - pH High/Low**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed a very high ph level greater than 8.0. Immediately lower the ph level so that it is 7.2-8.0. Spa is closed till this violation is corrected. Call me for reinspection.
	Not In Compliance Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed a cyanuric acid level greater than 100ppm. Lower the cyanuric acid level so that it is less than 100ppm.
	Not In Compliance Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**36K448 Equipment - Flow Meter**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Replace nonfunctioning flowmeter.
	Not In Compliance Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

**36K458 Maintenance - Test Kit/Daily Records**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no daily log of spa chlorine and ph levels. Maintain a daily log of these levels.
	Not In Compliance Violation Reference - CCR - 65523, 65529	

**Violation Description:** Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.


The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>VALENCIA LEA MHP</b>	DATE <b>6/9/2014</b>	SIGNATURE 
LOCATION <b>3850 E ATLANTIC AV, HIGHLAND, CA 92346</b>	REHS <b>Marilyn Krichbaum</b>	

**Overall Inspection Comments**

Identify filters. Label the flow of the water thru the recirculation system on the spa piping by using arrows.

**Photo Attachments:**

No Photo Attachments