



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME SHADY TRAILS PARKHOUSE				DATE 6/6/2014	SIGNATURE	
LOCATION 15800 S PARK LN, FONTANA, CA 92336				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 3/31/2015	
MAILING ADDRESS 15800 S PARK LN, FONTANA CA 92336				<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT REHS Chris Nwadike		
FA # FA0014449	PR # PR0019093	SR # Not Specified	CO # Not Specified	PE 3621	PROGRAM IDENTIFIER: Wading Pool	
TIME IN 12:24 PM	TIME OUT 1:12 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	85.0
observed flow (gpm)	50
required flow (gpm)	38
volume (gal)	2,246
area (sq ft)	256
occupancy	No Data

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed chlorine level at 1.0ppm. Maintain chlorine level between 1.5 and 10.0ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments