



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME PARC PLACE					DATE 6/11/2014	SIGNATURE	
LOCATION 13133 LE PARC , CHINO HILLS, CA 91709					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS PO BOX 5022, UPLAND CA 91785-5022					REHS Tin Nguyen		
FA # FA0003131	PR # PR0015479	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 1:57 PM	TIME OUT 2:27 PM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE



temperature (F)	102.0
observed flow (gpm)	No Data
required flow (gpm)	33
volume (gal)	1,000
area (sq ft)	50
occupancy	5

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS
NA

Compliance Date: Not Specified
Not In Compliance
Violation Reference - HSC

Inspector Comments:

-Spa permit is suspended due to high chlorine level at 20 ppm.
-Spa is ordered closed by Division of Environmental Health Services (DEHS). Do not open spa unless authorized by DEHS.

Contact DEHS at 1(800) 442-2283 when ready to re-open.

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K404 Water Quality - Critical - High Disinfectant Level

⚠ CRITICAL ⚠

POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed chlorine level above at 20 ppm in spa. Ensure chlorine level does not exceed 10 ppm.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K448 Equipment - Flow Meter

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 3125B

Inspector Comments: Observed flow meter stuck. Repair/replace flow meter to ensure flow rate is maintained at 33 gallons per minute (gpm).ski

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K460 Skimmers - Requirements

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65533, 3136B

Inspector Comments: Observed excessive high water level inside spa. Ensure water level in spa is maintained for proper skimming of debris.

Violation Description: The pool shall be equipped with one or more skimming methods to provide continuous skimming of the pool water and shall be capable of continually withdrawing not less than 75 percent of the required flow rate. Skimmers and water levels shall be maintained and operated to remove floating scum, sputum or debris continuously. The skimmer shall be recessed into the pool wall, individually adjustable for the rate of flow with either an external or internal device, provided with an air lock protective device and provided with a removable and cleanable screen or basket to trap objects.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME PARC PLACE	DATE 6/11/2014	SIGNATURE
LOCATION 13133 LE PARC , CHINO HILLS, CA 91709		REHS Tin Nguyen

36K466 Structure - Pool Shell

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed spa bottom/sides severely chipped. Re-plaster spa shell by next Summer 2015.
	Not In Compliance	
Violation Reference - CCR - 3108B		

Violation Description: The finished pool shell shall be lined with a smooth waterproof interior finish that will withstand repeated brushing, scrubbing, and cleaning procedures. The finish color shall be white. Tiles installed at the waterline shall be of contrasting color. A spa pool may be finished in a light color other than white when approved by the enforcing agent. Pool shell shall be maintained in good repair.

Overall Inspection Comments

pH: 7.2
Chlorine: 20.0 ppm
Cyanuric acid: > 100 ppm
Flow rate: n/a

NOTE:
-Keys provided to pool/spa gate has been changed and is no longer working. Per management, pool/spa keys will be mailed to Rancho Cucamonga office at 8575 Haven Avenue, Suite #130, Rancho Cucamonga, CA.

Photo Attachments:
No Photo Attachments