



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CAMBRIDGE SQUARE				DATE 6/12/2014	SIGNATURE	
LOCATION 2245 S FERN, ONTARIO, CA 91761				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 6/30/2014	
MAILING ADDRESS 1420 N CLAREMONT BL STE 205D, CLAREMONT CA 91711-3528				REHS Veronica Martinez		
FA # FA0008453	PR # PR0014534	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa	
TIME IN 11:34 AM	TIME OUT 12:42 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
				RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
				ACTION: 03 - REINSPECTION REQUIRED		

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

88

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K995 Permit - Suspension

CRITICAL

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Contact DEHS at 1(800) 442-2283 to request a re-inspection to re-open spa. Do not open spa for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K420 Temperature - Critical - Spa Water Requirement

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed the spa temperature at 119 F. Pool is ordered closed. Ensure spa temperature does not exceed 104 F.
	Not In Compliance	
	Violation Reference - CCR 24 - 3138B	

Violation Description: The allowable water temperature of a spa pool shall not exceed 104°F.

36K438 Enclosure - Critical - Gates Drowning Hazard

CRITICAL

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed gate without a keyless egress. Ensure exit of facility is available without the use of key.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

36K418 Water Quality - Cyanurates

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed cyanuric acid above 100 ppm. Maintain cyanuric acid below 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CAMBRIDGE SQUARE	DATE 6/12/2014	SIGNATURE
LOCATION 2245 S FERN , ONTARIO, CA 91761	REHS Veronica Martinez	

36K427 Safety - Safety Signs

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed the following safety signs missing: Emergency shut-off, telephone number to the nearest emergency service, name and street address of the pool facility. Provide and post.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."

Overall Inspection Comments

The spa is ordered closed. Contact DEHS at 1(800) 442-2283 to request a re-inspection to re-open spa. Do not open spa for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour

NOTE: Possible high chlorine level, unable to get accurate chlorine reading. Ensure chlorine level is maintained between 1.0 ppm and 10 ppm (1.5 in the presence of cyanuric acid).

Spa jets appear to be capped.

Unable to access pump room. Key does not open lock. Provide working key to pump room.

Photo Attachments:

No Photo Attachments