



County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>BELL GARDEN APARTMENTS</b>					DATE <b>6/13/2014</b>	SIGNATURE	
LOCATION <b>2050 S EUCLID, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>6/30/2015</b>	
MAILING ADDRESS <b>PO BOX 9037, BREA CA 92622</b>					REHS <b>Veronica Martinez</b>		
FA # <b>FA0005603</b>	PR # <b>PR0015017</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN <b>10:12 AM</b>	TIME OUT <b>10:58 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 03 - REINSPECTION REQUIRED		




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE



temperature (F)	No Data
observed flow (gpm)	55
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**



<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Contact DEHS at 1(800) 442-2283 to request a re-inspection to re-open pool. Do not open pool for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K404 Water Quality - Critical - High Disinfectant Level**



<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed chlorine level above 15 ppm. Pool is ordered closed. Ensure chlorine level is maintained between 1.0 ppm and 10 ppm (1.5 ppm in the presence of cyanuric acid).
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

**36K418 Water Quality - Cyanurates**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed cyanuric acid level above 100 ppm. Maintain cyanuric acid level below 100 ppm.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

**Overall Inspection Comments**

Observed chlorine level above 15 ppm. Pool is ordered closed. Ensure chlorine level is maintained between 1.0 ppm and 10 ppm (1.5 ppm in the presence of cyanuric acid).

Contact DEHS at 1(800) 442-2283 to request a re-inspection to re-open pool. Do not open pool for use unless authorized by DEHS. Non-compliance may result in future charged inspection at \$245.00 per hour.

**Photo Attachments:**

No Photo Attachments