





County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME PINECREST CHRISTIAN CONFERENCE CTR					DATE 6/12/2014	SIGNATURE	
LOCATION 1140 PINECREST RD, TWIN PEAKS, CA 92391					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014	
MAILING ADDRESS PO BOX 409, TWIN PEAKS CA 92391					REHS Breyanna Lyles		
FA # FA0006903	PR # PR0007973	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool		
TIME IN 4:30 PM	TIME OUT 4:35 PM	CONTACT Not Captured			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION		
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED		
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	0
volume (gal)	0
area (sq ft)	No Data
occupancy	No Data

36K994 Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: During the previous inspection the pool enclosure contained spaces measuring over 6 inches. During the follow-up inspection the operator has welded new bars in enclosure so that there are no spaces measuring over 4 inches.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments