



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | | | | | | |
|--|-----------------------------|--------------------------------|------------------------------|-------------------|---|---------------------------------------|--|
| FACILITY NAME ORCHARD MEADOWS II | | | | | DATE 6/12/2014 | SIGNATURE | |
| LOCATION 8320 VINEYARD, RANCHO CUCAMONGA, CA 91730 | | | | | REINSPECTION DATE Not Specified | PERMIT EXPIRATION 8/31/2014 | |
| MAILING ADDRESS 195 N EUCLID AV STE 100, UPLAND CA 91786 | | | | | REHS Anies Kondoker | | |
| FA # FA0007325 | PR # PR0014639 | SR # Not Specified | CO # Not Specified | PE 3620 | PROGRAM IDENTIFIER: Front Pool, Knollwood/Applewood | | |
| TIME IN 9:55 AM | TIME OUT 10:36 AM | CONTACT Not Captured | | | SERVICE: 001 - INSPECTION - ROUTINE | | |
| | | | | | RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ | | |
| | | | | | ACTION: 01 - NO FURTHER ACTION REQUIRED | | |

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE

| |
|-------------------|
| Ideal |
| In Compliance |
| Not in Compliance |



| | |
|---------------------|---------|
| temperature (F) | No Data |
| observed flow (gpm) | 110 |
| required flow (gpm) | 32 |
| volume (gal) | 15,400 |
| area (sq ft) | 500 |
| occupancy | 25 |

36K412 Water Quality - Non-Critical - Free/Combined Disinfectant Level

| | | |
|---------------------------|-----------------------------------|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Measured free chlorine at 1.0 ppm. Since cyanuric acid is present, maintain free chlorine level between 1.5 to 10 ppm. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65529 | |

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool. Combined chlorine/disinfectant shall not exceed approved level.

36K418 Water Quality - Cyanurates

| | | |
|---------------------------|-----------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Measured cyanuric acid above 100 ppm. Maintain at or below 100 ppm. |
| | Not In Compliance | |
| | Violation Reference - CCR - 65529 | |

Violation Description: The cyanuric acid concentration in any pool shall not exceeded 100 ppm.

36K427 Safety - Safety Signs

| | | |
|---------------------------|--------------------------------------|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed missing phone number of the nearest emergency services. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3120B | |

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

| | | |
|--|-------------------------------|-----------|
| FACILITY NAME ORCHARD MEADOWS II | DATE 6/12/2014 | SIGNATURE |
| LOCATION 8320 VINEYARD, RANCHO CUCAMONGA, CA 91730 | REHS Anies Kondoker | |

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

| | | |
|---------------------------|--|--|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed direction of flow for recirculation system not labeled. Ensure to clearly label recirculation equipment with directional symbols. |
| | Not In Compliance | |
| | Violation Reference - HSC - 3120B, 3132B, 3141B | |

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

36K452 Maintenance - Flow Rate/Turnover Time

| | | |
|---------------------------|---|---|
| POINTS 2 | Compliance Date: Not Specified | Inspector Comments: Observed flow rate at 110 gpm. The required flow rate for this pool is 32 gpm. Reduce flow rate to the level of the required rate. |
| | Not In Compliance | |
| | Violation Reference - CCR 24 - 3124B | |

Violation Description: The recirculation system shall have the capacity to provide a complete turnover of pool water in:

1. One-half hour or less for a spa pool;
2. One-half hour or less for a spray ground;
3. One hour or less for a wading pool;
4. Two hours or less for a medical pool; and
5. Six hours or less for all other types of public pools.

The variation in flow of an operating recirculation system shall be such as not to reduce the flow below 75 percent of the rate required.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments