



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT




www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME PROMONTORY				DATE 6/17/2014	SIGNATURE	
LOCATION 13156 PINNACLE CT, CHINO HILLS, CA 91709				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS 132 S ANITA DR STE 200, ORANGE CA 92868				REHS Tin Nguyen		
FA # FA0007322	PR # PR0014641	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool	
TIME IN 3:25 PM	TIME OUT 3:45 PM	CONTACT Not Captured			SERVICE: 008 - INSPECTION - ATTEMPTED	
					RESULT: 00 - NOT APPLICABLE	
					ACTION: 00 - NOT APPLICABLE	

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	87
volume (gal)	31,567
area (sq ft)	993
occupancy	50

36K996 Attempted Inspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: -Pool/spa was observed closed and drained at time of inspection. Per management, pool and spa has been drained to be re-plastered. Also, pool shell was cracked and pool return line was also leaking that needed to be repaired. NOTE: -Per management, pool/spa will be re-open within 3 weeks to a month.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: An inspection was attempted today. Another inspection will be attempted at a later date.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments