



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT



www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME COMFORT SUITES VICTORVILLE				DATE 6/19/2014	SIGNATURE
LOCATION 12281 MARIPOSA RD, VICTORVILLE, CA 92392				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 4/30/2015
MAILING ADDRESS PO BOX 2642, ORANGE CA 92859				REHS Veronica Vazquez	
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT				PROGRAM IDENTIFIER: Pool	
FA # FA0010898	PR # PR0013929	SR # Not Specified	CO # Not Specified	PE 3620	SERVICE: 037 - POOL/SPA - BILLABLE INSPECTION SERVICE
TIME IN 11:37 AM	TIME OUT 11:58 AM	CONTACT Not Captured			RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	85
volume (gal)	13,500
area (sq ft)	450
occupancy	22

36K993 Re-Reinspection

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Billable Re inspection conducted to verify ground-fault circuit interrupter (GFCI) was repaired/ replaced. Observed Ground fault circuit interrupter repaired. Observed pool lights on and turned off when GFCI was tested.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Billable re-reinspection conducted at the time to determine compliance from prior inspection.

Overall Inspection Comments

Call Veronica Vazquez at (800) 442-2283 with any questions.

Photo Attachments:

No Photo Attachments