



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME CAMP CEDAR FALLS				DATE 6/23/2014	SIGNATURE
LOCATION 3985 HWY 38, ANGELUS OAKS, CA 92305				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 12/31/2014
MAILING ADDRESS 39850 STATE HWY 38, ANGELUS OAKS CA 92305				REHS Robert Adams	
FA # FA0007080	PR # PR0004043	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool
TIME IN 1:06 PM	TIME OUT 1:42 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 01 - NO FURTHER ACTION REQUIRED

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

98

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	190
volume (gal)	64,500
area (sq ft)	1,500
occupancy	75

36K440 Enclosure - Non-Critical - Enclosure/Gates Non-Drowning Hazard

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed fencing less than 4 feet in height around the camp pool. Replace fencing with approvals from EHS plan check section (800)4420-2283, by June 1, 2015.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: The enclosure, doors and gates shall meet all requirements in the California Code of Regulations. Fencing/gates shall be maintained in good repair.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments