



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>24 HOUR FITNESS 197</b>				DATE <b>6/24/2014</b>	SIGNATURE	
LOCATION <b>11787 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>1/31/2015</b>	
MAILING ADDRESS <b>11787 FOOTHILL BL, RANCHO CUCAMONGA, CA 91730</b>				REHS <b>Nick Thalasinios</b>		
FA # <b>FA0011862</b>	PR # <b>PR0013585</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool	
TIME IN <b>4:40 PM</b>	TIME OUT <b>4:55 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 01 - CORRECTIVE ACTION NOT REQUIRED	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**100**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	160
required flow (gpm)	135
volume (gal)	48,578
area (sq ft)	1,524
occupancy	76

**No Violations Cited**

**Overall Inspection Comments**

No Pool Violations noted at this time.

**Photo Attachments:**

No Photo Attachments