



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>BROADSTONE SERRANO APARTMENTS</b>				DATE <b>6/26/2014</b>	SIGNATURE
LOCATION <b>1930 W COLLEGE AV, SAN BERNARDINO, CA 92407</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>12/31/2014</b>
MAILING ADDRESS <b>1930 W COLLEGE AV, SAN BERNARDINO CA 92407</b>				REHS <b>Patrick Baccari</b>	
FA # <b>FA0005802</b>	PR # <b>PR0014945</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3621</b>	PROGRAM IDENTIFIER: <b>Back Pool</b>
TIME IN <b>1:40 PM</b>	TIME OUT <b>2:10 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: <b>001 - INSPECTION - ROUTINE</b>
					RESULT: <b>03 - CORRECTIVE ACTION / NO FOLLOW UP REQ</b>
					ACTION: <b>01 - NO FURTHER ACTION REQUIRED</b>



**RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**90**

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**

**CRITICAL**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	Inspector Comments: <b>Chlorine was added to pool water.</b>
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 65529</b>	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K436 Enclosure - Critical - Enclosure Drowning Hazard**

**CRITICAL**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	Inspector Comments: <b>Remove logs and other things that can be climbed over to get inside pool enclosure.</b>
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR 24 - 3119B</b>	

**Violation Description:** The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows gates of living units or associated private premises shall not be permitted as part of the pool enclosure. The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children.

**36K454 Maintenance - Cleanliness**

<b>POINTS</b> <b>2</b>	Compliance Date: <b>Not Specified</b>	Inspector Comments: <b>Brush algae from pool shell.</b>
	<b>Not In Compliance</b>	
	Violation Reference - <b>CCR - 65533</b>	

**Violation Description:** Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments