



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME BIG BEAR FRONTIER					DATE 7/2/2014	SIGNATURE <i>Sara Rodriguez</i>	
LOCATION 40440 BIG BEAR BL, BIG BEAR LAKE, CA 92315					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS PO BOX 8000, WILMINGTON OH 45177					REHS Sierra Clayborn		
FA # FA0006804	PR # PR0013728	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa		
TIME IN 3:15 PM	TIME OUT 4:05 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		




RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

94

SCORE



temperature (F)	100.0
observed flow (gpm)	60
required flow (gpm)	30
volume (gal)	900
area (sq ft)	60
occupancy	6

36K402 Water Quality - Critical - Lack of Disinfectant



POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed spa at 0ppm chlorine during initial part of inspection.
	Not In Compliance	**Corrected during inspection. Remeasured chlorine at 6ppm.
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed flow meter at 60ppm with a slightly stuck bobbin.
	Not In Compliance	Investigate. Clean, repair or replace if necessary.
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments