



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>VILLAGE ON THE GREEN APARTMENTS</b>				DATE <b>7/2/2014</b>	SIGNATURE	
LOCATION <b>9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA, CA 91730</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>7/31/2014</b>	
MAILING ADDRESS <b>9400 FAIRWAY VIEW PL, RANCHO CUCAMONGA CA 91730</b>				REHS <b>Nick Thalasinios</b>		
FA # <b>FA0014399</b>	PR # <b>PR0019027</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool	
TIME IN <b>11:00 AM</b>	TIME OUT <b>11:30 AM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**96**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K438 Enclosure - Critical - Gates Drowning Hazard**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: <b>Not Specified</b>	<b>Inspector Comments:</b> Observed a club house door was not self-latching; The self-latching device shall keep the gate or door securely closed.  Corrected during inspection.
	Violation Reference - <b>HSC - 3119B</b>	

**Violation Description:** Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

**Overall Inspection Comments**

Pool Inspection

Please provide keys to the Pool and pump room areas.

**Photo Attachments:**

No Photo Attachments