



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME BAKER COMMUNITY SERVICES DISTRICT					DATE 7/2/2014	SIGNATURE	
LOCATION 72730 BAKER BL, BAKER, CA 92309					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS PO BOX 590, BAKER CA 92309					REHS John Ramos		
FA # FA0004876	PR # PR0016985	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool		
TIME IN 2:15 PM	TIME OUT 3:09 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

88

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	87.0
observed flow (gpm)	180
required flow (gpm)	230
volume (gal)	85,500
area (sq ft)	2,030
occupancy	105

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Comply by: 7/16/2014	Inspector Comments: Observed chlorine at 1.0 ppm. Maintain chlorine between 1.5 ppm and 10.0 ppm. Corrected to 2.5 ppm.
	Complied on 7/2/2014	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K436 Enclosure - Critical - Enclosure Drowning Hazard

⚠ CRITICAL ⚠

POINTS 4	Comply by: 7/4/2014	Inspector Comments: Observed illegal entry under the fence at the east end. Tie down fence. Corrected.
	Complied on 7/2/2014	
	Violation Reference - CCR 24 - 3119B	

Violation Description: The pool shall be enclosed by one or a combination of the following: a fence; portion of a building; wall; or other approved durable enclosure. Doors, windows gates of living units or associated private premises shall not be permitted as part of the pool enclosure. The enclosure shall have a minimum effective perpendicular height of 5 feet. Openings, holes or gaps in the enclosure, doors and/or gates shall not allow the passage of a 4-inch diameter sphere. The enclosure shall be constructed over a hard and permanent material equivalent to concrete. The enclosure shall be designed and constructed so that it cannot be readily climbed by small children.

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no life ring present in pool area. Provide a life ring in pool area.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them a 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME BAKER COMMUNITY SERVICES DISTRICT	DATE 7/2/2014	SIGNATURE
LOCATION 72730 BAKER BL, BAKER, CA 92309	REHS John Ramos	

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no directional arrows or markings on the piping. Provide markings.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

Overall Inspection Comments

Correct the above noted violations.

If you have any questions contact John Ramos at (800) 442-2283.

Photo Attachments:

No Photo Attachments