



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN					DATE 7/7/2014	SIGNATURE	
LOCATION 2155 E CONVENTION CENTER WY, ONTARIO, CA 91764					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 1/31/2015	
MAILING ADDRESS 2155 E CONVENTION CENTER WY, ONTARIO CA 91764					REHS Chaz Harrison		
FA # FA0016023	PR # PR0021307	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 10:48 AM	TIME OUT 11:15 AM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

88

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	21,368
area (sq ft)	695
occupancy	34

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit suspended due to lack of chlorine and water clarity.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed .5ppm chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K408 Water Quality - Critical - Clarity

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed main drain not clearly visible from the deck. Ensure water is kept sufficiently clear so that the main drain is visible from the deck.
	Not In Compliance	
	Violation Reference - CCR - 65527, 65543	

Violation Description: The recirculation and purification system shall be operated and maintained so as to keep the pool water clean and clear. Under no circumstances shall the pool be used if the main drain is not clearly visible from the deck. The water of every wading pool shall be kept sufficiently clear so that the bottom of the wading pool will be visible at all times.

36K430 Safety - Equipment/First Aid Kit

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed no rope attached to life ring. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Violation Description: Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them a 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN	DATE 7/7/2014	SIGNATURE
LOCATION 2155 E CONVENTION CENTER WY, ONTARIO, CA 91764		REHS Chaz Harrison

36K444 Equipment - Recirculation Pump/Filter/Separation Tank

POINTS 2	Compliance Date: Not Specified	Inspector Comments: The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area. Observed no direction of flow on recirculation equipment in pump room.
	Not In Compliance Violation Reference - HSC - 3120B, 3132B, 3141B	

Violation Description: Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

Overall Inspection Comments

Do not open pool/spa without approval from San Bernardino County Environmental Health Services.
The pool permit is hereby suspended. The pool is to remain closed until all critical violations are corrected.
Closure sign was posted at gate and was secured with a zip tie. Do not re-open pool or remove sign without written approval from this department. Doing so will result in a \$245.00 hr re-posting fee.
Call Chaz Harrison at 909-648-7510 to re-open.

Photo Attachments:
No Photo Attachments