



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME HOLIDAY INN				DATE 7/7/2014	SIGNATURE	
LOCATION 2155 E CONVENTION CENTER WY, ONTARIO, CA 91764				REINSPECTION DATE Not Specified	PERMIT EXPIRATION 1/31/2015	
MAILING ADDRESS 2155 E CONVENTION CENTER WY, ONTARIO CA 91764				REHS Chaz Harrison		
FA # FA0016023	PR # PR0021308	SR # Not Specified	CO # Not Specified	PE 3623	PROGRAM IDENTIFIER: Spa	
TIME IN 11:15 AM	TIME OUT 12:13 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility



Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

96

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	2,200
area (sq ft)	79
occupancy	8

36K406 Water Quality - Critical - pH High/Low

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed pH level above 8.0. Ensure to bring pH level between 7.2-8.0. Use Muriatic Acid to decrease the Total Alkalinity of pool. Corrected on Site.
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments