



County of San Bernardino • Department of Public Health
 Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME MONTIERRA APARTMENTS					DATE 7/7/2014	SIGNATURE	
LOCATION 1701 E D ST, ONTARIO, CA 91764					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 8/31/2014	
MAILING ADDRESS 1701 E D ST, ONTARIO, CA 91764					REHS Chaz Harrison		
FA # FA0003650	PR # PR0013556	SR # Not Specified	CO # Not Specified	PE 3621	PROGRAM IDENTIFIER: Back Pool		
TIME IN 2:03 PM	TIME OUT 2:30 PM	CONTACT Not Captured			SERVICE: 001 - INSPECTION - ROUTINE		
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED		
					ACTION: 14 - PERMIT SUSPD / FACILITY CLOSED FENCING		



RECREATIONAL HEALTH - Public Pool - Additional Pool at Facility

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

92

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	40
volume (gal)	13,900
area (sq ft)	532
occupancy	26

36K995 Permit - Suspension

⚠ CRITICAL ⚠

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Permit suspended due to lack of chlorine and entry gate not self closing.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

36K402 Water Quality - Critical - Lack of Disinfectant

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).
	Not In Compliance	
	Violation Reference - CCR - 65529	

Violation Description: For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

36K438 Enclosure - Critical - Gates Drowning Hazard

⚠ CRITICAL ⚠

POINTS 4	Compliance Date: Not Specified	Inspector Comments: Observed north entry gate not self closing. Ensure all entry gates are self closing. Entry gate observed open at time of inspection.
	Not In Compliance	
	Violation Reference - HSC - 3119B	

Violation Description: Gates and doors shall be equipped with self-closing and self-latching devices. The self-latching device shall keep the gate or door securely closed. Gates and doors shall open outwardly away from the pool except where otherwise prohibited by law. Gates and doors shall be capable of being locked during times when the pool is closed. The pool enclosure shall have at least one means of egress without a key for emergency purposes.

Overall Inspection Comments

Do not open pool/spa without approval from San Bernardino County Environmental Health Services. The pool permit is hereby suspended. The pool is to remain closed until all critical violations are corrected.

Closure sign was posted at gate and was secured with a zip tie. Do not re-open pool or remove sign without written approval from this department. Doing so will result in a \$245.00 hr re-posting fee.

Call Chaz Harrison at 909-648-7510 to re-open.

Photo Attachments:

No Photo Attachments