



**County of San Bernardino • Department of Public Health
Division of Environmental Health Services
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME SUPER 8 MOTEL					DATE 7/10/2014	SIGNATURE 	
LOCATION 225 E HOSPITALITY LN, SAN BERNARDINO, CA 92408					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 5/31/2015	
MAILING ADDRESS 225 E HOSPITALITY LN, SAN BERNARDINO, CA 92408					REHS Amanda Gaspard		
FA # FA0008843	PR # PR0015821	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN 2:25 PM	TIME OUT 3:16 PM	CONTACT Not Captured			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

90

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	87.0
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	15

36K404 Water Quality - Critical - High Disinfectant Level



POINTS
4

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR - 65529

Inspector Comments: Observed free chlorine residual in excess of 10.0 ppm. Stabilizer (cyanuric acid) is being utilized.

Ensure that free chlorine level is between 1.5 and 10.0 ppm (since cyanuric acid is being utilized as a stabilizer). If a stabilizer is not used, ensure that chlorine level is between 1.0 and 10.0 ppm.

The pool is now closed due to high free chlorine levels. Contact the County of San Bernardino, Division of Environmental Health Services (DEHS) when compliance is reached. Maintain pool closed until re-opened by DEHS inspector.

Violation Description: Concentration of available disinfectant shall not exceed approved level. Free chlorine residual shall not exceed 10 ppm.

36K427 Safety - Safety Signs

POINTS
2

Compliance Date: Not Specified
Not In Compliance
Violation Reference - CCR 24 - 3120B

Inspector Comments: Observed that the following signs are missing:
1) Sign with the name AND street address of the facility.
2) The telephone number of the nearest local emergency services [note: this is in addition to the 911 sign].

This is a repeat violation.

Provide signs.

Violation Description: All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- a) Maximum number of pool users permitted for each pool.
- b) "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- c) Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- d) An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- e) The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- f) A warning sign for spa pools with "CAUTION" language.
- g) Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- h) A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- i) A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- j) A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- k) A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
 RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME SUPER 8 MOTEL	DATE 7/10/2014	SIGNATURE
LOCATION 225 E HOSPITALITY LN, SAN BERNARDINO, CA 92408		REHS Amanda Gaspard

36K448 Equipment - Flow Meter

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed that the flow meter was non-functional / stuck. This is a repeat violation.
	Not In Compliance	Repair / replace flow meter; maintain flow meter functional and in good repair.
	Violation Reference - CCR - 3125B	

Violation Description: A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

36K454 Maintenance - Cleanliness

POINTS 2	Compliance Date: Not Specified	Inspector Comments: Observed a large amount of debris (leaves, insects, etc.) floating in the pool.
	Not In Compliance	Remove debris. Clean thoroughly and regularly, and maintain free of debris.
	Violation Reference - CCR - 65533	

Violation Description: Floating scum, sputum or debris shall not be allowed to accumulate in the pool. The bottom and sides of the pool shall be cleaned as often as necessary to be kept in a clean condition. The sides and bottom of pools, decks and other surfaces shall be kept free of slime and algae.

Overall Inspection Comments

No summary comments have been made for this inspection.

Photo Attachments:

No Photo Attachments