



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**




(800) 442-2283

www.sbcounty.gov/dph/dehs

FACILITY NAME LAS BRISAS FONTANA HOA					DATE 7/14/2014	SIGNATURE	
LOCATION 9240 DATE ST, FONTANA, CA 92335					REINSPECTION DATE Not Specified	PERMIT EXPIRATION 10/31/2014	
MAILING ADDRESS 3756 TIBBETTS ST, RIVERSIDE CA 92506					REHS Patrick Baccari		
FA # FA0008400	PR # PR0015763	SR # Not Specified	CO # Not Specified	PE 3620	PROGRAM IDENTIFIER: Pool		
TIME IN 1:57 PM	TIME OUT 2:03 PM	CONTACT Not Captured			SERVICE: 008 - INSPECTION - ATTEMPTED		
					RESULT: 00 - NOT APPLICABLE		
					ACTION: 00 - NOT APPLICABLE		

RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

36K488 AB 1020 - Critical - Non-Compliant Pool/Spa **⚠ CRITICAL ⚠**

POINTS NA	Compliance Date: Not Specified	Inspector Comments: Pool and spa still observed closed as required per non compliance with AB 1020.
	Not In Compliance	
	Violation Reference - CCR	

Violation Description: Pool or spa is in violation of State Assembly Bill 1020, the Anti- Entrapment Devices and System Law for Public Swimming Pools. The compliance date of July 1, 2010 has passed. Compliance with AB 1020 is required. Health Permit is suspended, and the pool/spa is posted closed at this time. A drained pool/spa shall remain closed and secured until plans have been submitted to and approved by DEHS and all related construction finalized. Pool/spa shall meet all current health code requirements including compliance with AB 1020. If pool/spa is to be demolished, approval from Building and Safety must be obtained. Submit copy of finalized building permit to EHS for permit inactivation.

Overall Inspection Comments

Wendy 989 222

Photo Attachments:
No Photo Attachments