



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**



www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>SUPER 8 MOTEL</b>				DATE <b>7/15/2014</b>	SIGNATURE 
LOCATION <b>225 E HOSPITALITY LN, SAN BERNARDINO, CA 92408</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>5/31/2015</b>
MAILING ADDRESS <b>225 E HOSPITALITY LN, SAN BERNARDINO, CA 92408</b>				REHS <b>Amanda Gaspard</b>	
FA # <b>FA0008843</b>	PR # <b>PR0015821</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3620</b>	PROGRAM IDENTIFIER: Pool
TIME IN <b>3:39 PM</b>	TIME OUT <b>3:56 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ
					ACTION: 15 - PERMIT REINSTATED / FACILITY RE-OPENED

**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	15

**36K992 Permit Reinstatement**

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: Permit is re-instated.
	Not In Compliance	
	Violation Reference - HSC	

Violation Description: The health permit to operate is hereby reinstated and facility may open.

**36K994 Reinspection**

POINTS <b>NA</b>	Compliance Date: Not Specified	Inspector Comments: During the routine inspection on 07-10-14, pool was closed due to excessively high free chlorine levels.
	Not In Compliance	Facility has requested a re-inspection.
	Violation Reference - HSC	During the re-inspection on 07-15-14, observed free chlorine level at 1.2 ppm and pH at 7.3.

Ensure that free chlorine level is between 1.5 and 10.0 ppm (since cyanuric acid is being utilized as a stabilizer).

Violation Description: Reinspection conducted at this time to determine compliance from prior inspection.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments