



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>FONTANA HIGH SCHOOL</b>				DATE <b>7/16/2014</b>	SIGNATURE	
LOCATION <b>9453 CITRUS AV, FONTANA, CA 92335</b>				REINSPECTION DATE <b>1/16/2015</b>	PERMIT EXPIRATION	
MAILING ADDRESS <b>9680 CITRUS AV, FONTANA CA 92335</b>				REHS <b>Patrick Baccari</b>		
FA # <b>FA0005773</b>	PR # <b>PR0014957</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3603</b>	PROGRAM IDENTIFIER: Pool	
TIME IN <b>11:59 AM</b>	TIME OUT <b>12:42 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 001 - INSPECTION - ROUTINE	
					RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ	
					ACTION: 01 - NO FURTHER ACTION REQUIRED	

**RECREATIONAL HEALTH - Public School Pool / Spa**




Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**92**

SCORE

Ideal
In Compliance
Not in Compliance



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Chlorine level was observed at 0.5 ppm. Increase free available chlorine level to 1.0 - 10.0 ppm. Pool employee was left message to increase free available chlorine level prior to opening pool for use..
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K430 Safety - Equipment/First Aid Kit**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Maximum number of pool users permitted for each pool.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."

An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.

The emergency telephone number 911, the number of the nearest emergency services and the name and street address of the pool facility.

Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."

A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP CLOSED."

A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
 RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>FONTANA HIGH SCHOOL</b>	DATE <b>7/16/2014</b>	SIGNATURE
LOCATION <b>9453 CITRUS AV, FONTANA, CA 92335</b>	REHS <b>Patrick Baccari</b>	

**36K434 Supervision - Lifeguards**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Replace damaged wheels to lifeguard platforms.
	Not In Compliance	
	Violation Reference - HSC - 65521, 65537, 116033...	

**Violation Description:** Every pool shall be under the supervision of a person who is fully capable of, and shall assume responsibility for, compliance with all requirements relating to pool operation, maintenance and safety of bathers.

Persons providing aquatic instruction shall possess current certificates from an American Red Cross or YMCA of the U.S.A. lifeguard training program, or have equivalent qualifications, as determined by DEHS. In addition, these persons shall be certified in standard first aid and cardiopulmonary resuscitation (CPR).

Lifeguard service shall be provided for any public swimming pool that is of wholly artificial construction and for the use of which a direct fee is charged. The number of lifeguards shall be adequate to maintain continuous surveillance over the bathers. For all other public swimming pools, lifeguard service shall be provided or signs shall be erected clearly indicating that the service is not provided.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments