



County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

(800) 442-2283

FACILITY NAME <b>RADISSON ONTARIO AIRPORT</b>					DATE <b>7/17/2014</b>	SIGNATURE	
LOCATION <b>2200 E HOLT BL, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>8/31/2014</b>	
MAILING ADDRESS <b>2155 E CONVENTION CENTER WY, ONTARIO CA 91764</b>					REHS <b>Chaz Harrison</b>		
<input type="checkbox"/> FACILITY <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> ACCOUNT					PROGRAM IDENTIFIER: Spa		
FA # <b>FA0006518</b>	PR # <b>PR0013910</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN <b>2:19 PM</b>	TIME OUT <b>3:04 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 03 - CORRECTIVE ACTION / NO FOLLOW UP REQ		
					ACTION: 01 - NO FURTHER ACTION REQUIRED		



**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**94**

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant**



POINTS <b>4</b>	Compliance Date: Not Specified	Inspector Comments: Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid). Corrected on site.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K430 Safety - Equipment/First Aid Kit**

POINTS <b>2</b>	Compliance Date: Not Specified	Inspector Comments: Observed no rope attached to life ring. All swimming pools are required to provide a life ring with an outside diameter of 17 inches and a rope (at least 3/16 inches in diameter) attached that is long enough to span the widest part of the pool.
	Not In Compliance	
	Violation Reference - CCR - 65539	

Observed body hook in disrepair. Ensure to repair or replace body hook.

**Violation Description:** Every swimming pool shall be equipped for safety and rescue purposes with one or more rescue poles not less than 12 feet in length with body hooks, and one or more life rings having a minimum exterior diameter of 17 inches readily accessible for use. Such life rings shall have attached to them an 3/16 inch line long enough to span the maximum width of the pool. A first aid kit shall be provided at all swimming pools when required by DEHS.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**  
No Photo Attachments