






County of San Bernardino • Department of Public Health  
 Division of Environmental Health Services  
**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM**  
**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME <b>RODEWAY INN</b>				DATE <b>7/23/2014</b>	SIGNATURE <i>Patrick Baccari</i>
LOCATION <b>4075 E GUASTI RD, ONTARIO, CA 91761</b>				REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>1/31/2015</b>
MAILING ADDRESS <b>4075 E GUASTI RD, ONTARIO, CA 91761</b>				REHS <b>Patrick Baccari</b>	
FA # <b>FA0008435</b>	PR # <b>PR0014172</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa
TIME IN <b>11:45 AM</b>	TIME OUT <b>12:06 PM</b>	CONTACT <b>Not Captured</b>			SERVICE: 003 - INSPECTION - FOLLOW UP INSPECTION
					RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED
					ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED

**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K402 Water Quality - Critical - Lack of Disinfectant** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Zero free chlorine available in spa water. Maintain chlorine level between 1.0 - 10.0 ppm
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K406 Water Quality - Critical - pH High/Low** ⚠ CRITICAL ⚠

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Adjust Ph to an ideal value 7.4 - 7.6, 7.2-8.0 is required.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.

**36K458 Maintenance - Test Kit/Daily Records**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

**Violation Description:** Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**  
No Photo Attachments