



**County of San Bernardino • Department of Public Health  
Division of Environmental Health Services  
COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>RODEWAY INN</b>					DATE <b>7/29/2014</b>	SIGNATURE	
LOCATION <b>4075 E GUASTI RD, ONTARIO, CA 91761</b>					REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>1/31/2015</b>	
MAILING ADDRESS <b>4075 E GUASTI RD, ONTARIO, CA 91761</b>					REHS <b>Chaz Harrison</b>		
FA # <b>FA0008435</b>	PR # <b>PR0014172</b>	SR # <b>Not Specified</b>	CO # <b>Not Specified</b>	PE <b>3623</b>	PROGRAM IDENTIFIER: Spa SERVICE: 001 - INSPECTION - ROUTINE		
TIME IN <b>2:43 PM</b>	TIME OUT <b>3:39 PM</b>	CONTACT <b>Not Captured</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQUIRED ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED		




**RECREATIONAL HEALTH - Public Pool - Additional Spa at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

**90**

SCORE



temperature (F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	No Data
volume (gal)	No Data
area (sq ft)	No Data
occupancy	No Data

**36K995 Permit - Suspension**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>NA</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Pool Permit suspended due to lack of chlorine and pH.
	Not In Compliance	
	Violation Reference - HSC	

**Violation Description:** Violation(s) observed pose an immediate threat to public health and safety. The health permit to operate is hereby suspended and the pool/spa ordered closed until the listed violation(s) have been corrected and verified by Environmental Health Services (EHS). The facility is to remain closed until permission from EHS is given. Contact your inspector at your local office to schedule a reinspection to reinstate the health permit. The facility is posted closed; do not move, hide, or remove the sign. Reopening of the pool/spa without the approval by EHS, may result in an hourly billable Professional Services fee.

**36K402 Water Quality - Critical - Lack of Disinfectant**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed no chlorine detected at time of inspection; Maintain a minimum of 1.5 ppm of free chlorine when pool is open for use. (1.0 ppm without cyanuric acid).
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K406 Water Quality - Critical - pH High/Low**

**⚠ CRITICAL ⚠**

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Observed pH level below 7.2. Ensure to bring pH level between 7.2-8.0. Use Soda Ash to increase the total alkalinity of pool.
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** Water shall be maintained in an alkaline condition at a pH between 7.2 and 8.0.



**COMMUNITY ENVIRONMENTAL HEALTH PROGRAM  
RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

[www.sbcounty.gov/dph/dehs](http://www.sbcounty.gov/dph/dehs)

**(800) 442-2283**

FACILITY NAME <b>RODEWAY INN</b>	DATE <b>7/29/2014</b>	SIGNATURE
LOCATION 4075 E GUASTI RD, ONTARIO, CA 91761		REHS <b>Chaz Harrison</b>

**36K458 Maintenance - Test Kit/Daily Records**

<b>POINTS</b>  <b>2</b>	Compliance Date: Not Specified	<p><b>Inspector Comments:</b> Observed no test kit. Ensure to obtain a DPD test kit. Observed no daily pool records on site. Ensure to maintain daily records for pool. Pool Code sec. 65523 states: "The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used." Also it states: "If cyanuric acid is used..., the cyanuric acid concentration shall be measured a minimum of once per month and records shall be kept of the results of such testing." If the pool service person is only at the site 3 days a week, there needs to be someone else to record the chlorine and pH on the other 4 days. The only way poor chemistry can be corrected is if someone knows that it is "poor."</p>
	<p><b>Not In Compliance</b></p> <p>Violation Reference - CCR - 65523, 65529</p>	

**Violation Description:** Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

**Overall Inspection Comments**

No summary comments have been made for this inspection.

**Photo Attachments:**

No Photo Attachments